COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF SOUTH LOGAN WATER)
ASSOCIATION, INC. FOR A DEVIATION FROM)
THE REQUIREMENTS OF 807 KAR 5:066,) CASE NO. 91-024
SECTION 5(4) REGARDING WATER STORAGE)

ORDER

By application received January 18, 1991, South Logan Water Association, Inc. ("South Logan") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. South Logan states in its application that its average daily water usage, including unaccounted-for water, is approximately 334,843 gallons, and that its current water storage capacity is 200,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

- 1. South Logan is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).
- 2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, South Logan should be given until July 1, 1994 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).

IT IS THEREFORE ORDERED that:

- 1. South Logan be and it hereby is given until July 1, 1994 to comply with the provisions of 807 KAR 5:066, Section 5(4).
- 2. South Logan shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1994.

Done at Frankfort, Kentucky, this 15th day of February, 1991.

PUBLIC SERVICE COMMISSION

Chairman

Vice Charman

Commissioner

ATTEST:

Sel Meetrechen